



RETAINING WALL NOTES

1. Ø100mm RIGID SLOTTED uPVC SUB-SOIL AGRICULTURAL PIPE WITH FILTER SOCK (ON MIN. 0.5% FALL) TO NEAREST AVAILABLE STORMWATER PIT
2. 150mm SURROUND OF 20mm BLUE METAL OR GRAVEL
3. REINFORCEMENT PER AS 3600, WALL TIES TYPE A AS 2699.1
4. PROVIDE BRICK FACADE CLEAN-OUT BLOCK AT BASE OF RETAINING WALL. OMIT HORIZONTAL BAR FROM TOP OF THIS BLOCK.
5. DESIGN STANDARDS ACCORDING TO AS 3700 (MASONRY STRUCTURES) DAMP-PROOF COURSE INSTALLED ABOVE FOUNDATION LEVEL, COMPLIANT WITH AS 2904
6. WEEP HOLES AT BASE, SPACED AT 1000 , INTERVALS WITH CAVITY OF 50 MM MINIMUM TO 110 MM MAXIMUM

REF.	DESCRIPTION	QTY.	PL.	REF.	MATERIAL	SPECIFICATIONS	OBSERVATION
<h2 style="text-align: center;">ENGINEERING BUILDING & INFRASTRUCTURE</h2>							
Retaining Wall Specifications							
		Reverine Park				SCALE: 0.5:1	
						DATE: 20/04/2025	
		Designer: Ahmad Samadi					
		Position: Multidisciplinary Engineer - Structural				PL. No.:	